

Go Direct[®] Motion

(Order Code GDX-MD)



Go Direct Motion accurately tracks objects as close as 15 cm and as far away as 3.5 m. The compact design and wireless capabilities of this motion detector eliminate the concern of a dangling cable getting in the way.

Use the temperature compensation channel of Go Direct Motion to adjust for the difference in the speed of sound in cold and warm locations.

Go Direct Motion can be used in a variety of experiments:

- Study position, velocity, and acceleration of carts on a track.
- Match graphs created in data-collection software.
- Analyze the effects of air resistance on falling coffee filters.
- Investigate simple harmonic motion by monitoring a mass on a spring.

Note: Vernier products are designed for educational use. Our products are not designed nor are they recommended for any industrial, medical, or commercial process such as life support, patient diagnosis, control of a manufacturing process, or industrial testing of any kind.

What's Included

- Go Direct Motion
- Micro USB Cable

Compatible Software

See www.vernier.com/manuals/gdx-md for a list of software compatible with Go Direct Motion.

Getting Started

Please see the following link for platform-specific connection information:

www.vernier.com/start/gdx-md

Bluetooth Connection

1. Install Vernier Graphical Analysis[™] on your computer, Chromebook[™], or mobile device. If using LabQuest[®], make sure LabQuest App is up to date. See www.vernier.com/ga4 for Graphical Analysis availability or www.vernier.com/downloads to update LabQuest App.
2. Charge your sensor for at least 2 hours before first use.
3. Turn on your sensor by pressing the power button once. The Bluetooth[®]

USB Connection

1. If using a computer or Chromebook, install Vernier Graphical Analysis. If using LabQuest, make sure LabQuest App is up to date. See www.vernier.com/ga4 for Graphical Analysis availability or www.vernier.com/downloads to update LabQuest App.
2. Connect the sensor to the USB port.
3. Launch Graphical Analysis or turn on LabQuest. You are now ready to

LED will blink red.

4. Launch Graphical Analysis or turn on LabQuest.
5. If using Graphical Analysis, click or tap Sensor Data Collection. If using LabQuest, choose Wireless Device Setup > Go Direct from the Sensors menu.
6. Select your Go Direct sensor from the list of Discovered Wireless Devices. Your sensor's ID is located near the barcode on the sensor. The Bluetooth LED will blink green when it is successfully connected.
7. Click or tap Done. You are now ready to collect data.
8. This is a multi-channel sensor. To change the channel selections, see www.vernier.com/start/gdx-md

collect data.

4. This is a multi-channel sensor. To change the channel selections, see www.vernier.com/start/gdx-md

Note: This sensor does not work with the original LabQuest. It works with LabQuest 2 or LabQuest 3.

Charging the Sensor

Connect Go Direct Motion to the included USB Charging Cable and any USB device for two hours.

You can also charge up to eight Go Direct Motion Detectors using our Go Direct Charge Station, sold separately (order code: GDX-CRG). An LED on each Go Direct Motion indicates charging status.

| | |
|---------------|---|
| Charging | Orange LED next to the battery icon is solid while the sensor is charging. |
| Fully charged | Green LED next to the battery icon is solid when the sensor is fully charged. |

Powering the Sensor

| | |
|----------------------------------|---|
| Turning on the sensor | Press button once. Red LED indicator flashes when unit is on. |
| Putting the sensor in sleep mode | Press and hold button for more than three seconds to put into sleep mode. Red LED indicator stops flashing when sleeping. |

Connecting the Sensor

See the following link for up-to-date connection information:

www.vernier.com/start/gdx-md

Connecting via Bluetooth

| | |
|------------------|---|
| Ready to connect | Red LED next to the Bluetooth icon flashes when sensor is awake and ready to connect. |
| Connected | Green LED next to the Bluetooth icon flashes when sensor is connected via Bluetooth. |

Connecting via USB

| | |
|---|--|
| Connected and charging | Orange LED next to the battery icon is solid when the sensor is connected to Graphical Analysis via USB and the unit is charging. LED next to Bluetooth icon is off. |
| Connected, fully charged | Green LED next to the battery icon is solid when the sensor is connected to Graphical Analysis via USB and fully charged. LED next to Bluetooth icon is off. |
| Charging via USB, connected via Bluetooth | Orange LED next to the battery icon is solid when the sensor is charging. Green LED next to the Bluetooth icon flashes. |

Identifying the Sensor

When two or more sensors are connected, the sensors can be identified by tapping or clicking Identify in Sensor Information.

Using the Product

Connect the sensor following the steps in the Getting Started section of this user manual.

Channels

Go Direct Motion has three measurement channels. The channel names are

- Motion
- Motion (cart)
- Motion with TC

Motion

The default channel that is active when the sensor is connected is motion. The motion channel is set to measure the distance between the sensor and the nearest object based on the speed of sound at 22°C. This channel has a high gain and is best for most uses, such as measuring the motion of a tossed ball, a walking student, or a mass on a spring.

Motion (cart)

This channel has a lower gain setting than the default motion channel. It is useful for measuring a cart on a track as this channel is less likely to pick up

objects to either side of the track. Use this channel for small objects close to the motion detector.

Motion with TC

Use the motion with TC channel for automatic temperature compensation, which adjusts the speed of sound used in the distance calculation based on an internal temperature sensor. This is particularly useful if you are using the sensor in an environment that is much warmer or much cooler than room temperature.

Videos

View videos related to this product at www.vernier.com/gdx-md

Calibrating the Sensor

You can make several adjustments to the readings by zeroing and changing the direction of the coordinate system. You can find details on how to adjust these readings at www.vernier.com/til/2972

Motion and Motion (cart) Channels

The default for this channel uses the speed of sound at 22°C. If you would like to calibrate the sensor to improve accuracy, place a hard, flat surface (such as a wall, book, or box) a known distance away from the front surface of Go Direct Motion and choose calibrate. Note that the calibration will be saved to the sensor, so the next time you use this channel it will use the previously saved value.

Motion with TC Channel

This channel adjusts automatically based on the temperature and cannot be calibrated.

Specifications

| | |
|--------------------------|---|
| Range | Motion and Motion with TC channels: 0.25 m to 3.5 m Motion (cart) channel: 0.15 m to 3.5 m |
| Resolution | 1 mm |
| Temperature compensation | Motion and Motion (cart) channels: Factory calibrated for room temperature. Calibrate to a known distance for improved distance accuracy. Motion with TC channel: Uses internal temperature sensor to respond to dynamic temperature changes |
| Accuracy | 2 mm |
| Ultrasound frequency | 50 kHz |
| Power consumption | 51 mA |
| Maximum sampling rate | 30 samples/s |

| | |
|-----------------------------------|--|
| USB specification | USB 2.0 full speed |
| Wireless specification | Bluetooth v4.2 |
| Maximum wireless range | 30 m (unobstructed) |
| Battery | 650 mA Li-Poly |
| Battery life (single full charge) | ~24 hours |
| Battery life (long term) | ~500 full charge cycles (several years depending on usage) |

Care and Maintenance

Battery Information

Go Direct Motion contains a small lithium-ion battery. The system is designed to consume very little power and not put heavy demands on the battery. Although the battery is warranted for one year, the expected battery life should be several years. Replacement batteries are available from Vernier (order code: GDX-BAT-650).

Storage and Maintenance

To store Go Direct Motion for extended periods of time, put the device in sleep mode by holding the button down for at least three seconds. The red LED will stop flashing to show that the unit is in sleep mode. Over several months, the battery will discharge but will not be damaged. After such storage, charge the device for a few hours, and the unit will be ready to go.

Exposing the battery to temperatures over 35°C (95°F) will reduce its lifespan. If possible, store the device in an area that is not exposed to temperature extremes.


Water Resistance

Go Direct Motion is not water resistant and should never be immersed in water.

If water gets into the device, immediately power the unit down (press and hold the power button for more than three seconds). Disconnect the sensor and charging cable, and remove the battery. Allow the device to dry thoroughly before attempting to use the device again. Do not attempt to dry using an external heat source.

How the Sensor Works

Go Direct Motion emits short bursts of ultrasonic sound waves from the gold foil of the transducer. These waves fill a cone-shaped area about 15 to 20° off the axis of the center line of the beam. Go Direct Motion then “listens” for the echo of these ultrasonic waves returning to it. The equipment measures how long it takes for the ultrasonic waves to make the trip from Go Direct Motion to an object and back. Using this time and the speed of sound in air, the distance to the nearest object is determined.



Note that Go Direct Motion will report the distance to the closest object that produces a sufficiently strong echo. Go Direct Motion can pick up objects such as chairs and tables in the cone of ultrasound.

The sensitivity of the echo detection circuitry automatically increases, in steps, every few milliseconds as the ultrasound travels out and back. This change in sensitivity enables the detection of weaker signals.

Troubleshooting

The most frequently reported problems with a motion detector are that the motion does not work beyond a certain distance or that the graph is very noisy. There are a number of ways to troubleshoot these situations, and they are described below.

1. If Go Direct Motion does not work beyond a certain distance (e.g., it does not detect anything beyond 1.2 m), here are some things to check if you have this problem:
 - Check for movable objects (textbooks, ring stands, etc.) in the cone of the ultrasound. If possible, move these objects out of the measurement cone. It may not take a very large object to cause problems.
 - Check for a stationary object (chair, table, etc.) in the cone of the ultrasound. This object may be detected when you are trying to study an object farther away. It may not take a very large object to cause problems. If you have trouble with a stationary object causing unwanted echoes, try setting the equipment up so that the objects are not in the cone or placing a cloth over the object. This minimizes the ultrasound reflection.
3. Noisy or erratic data may have a number of causes. Here are some tips.
 - Sometimes other sound sources can cause problems. If there is another source of ultrasonic waves in the same frequency range, this will cause erroneous readings. Examples include motors and fans, air track blowers, the sound made by the air exiting the holes on an air track, etc. Try to eliminate these sources of noise. If you are using an air track, try changing the air flow volume.
 - Make sure that Go Direct Motion is not placed close to a computer or computer monitor.
 - If the room in which Go Direct Motion is being used has a lot of hard, sound-reflecting surfaces, you can get strange effects caused by the

ultrasound bouncing around the room. Standing waves can be set up between Go Direct Motion and a sound reflector. Try placing a cloth horizontally just in front of and below the Motion Detector. This sometimes helps eliminate ultrasound that is “skipping” into the Go Direct Motion.

- Try changing the data-collection rate. Sometimes motion detectors work better at one data rate than another. Rates above 30 Hz do not work well in acoustically live rooms.
- If you are studying people moving, have them hold a large, flat object (e.g., a large book or a pizza box) as a reflector. If you have an irregular reflecting surface, sometimes the waves will be reflected back to the transducer, and sometimes not. The results will seem erratic.

An excellent discussion of motion detector theory and operation can be found in “Physics and Technical Characteristics of Ultrasonic Sonar Systems”, Dan MacIsaac and Ari Hamalainen, *The Physics Teacher* 40, 39–46 (January 2002).

For additional troubleshooting and FAQs, see www.vernier.com/tit/4112

Repair Information

If you have watched the related product video(s), followed the troubleshooting steps, and are still having trouble with your Go Direct Motion, contact Vernier Technical Support at support@vernier.com or call 888-837-6437. Support specialists will work with you to determine if the unit needs to be sent in for repair. At that time, a Return Merchandise Authorization (RMA) number will be issued and instructions will be communicated on how to return the unit for repair.

Accessories/Replacements

| Item | Order Code |
|---------------------------------------|----------------|
| Micro USB Cable | CB-USB-MICRO |
| USB-C to Micro USB Cable | CB-USB-C-MICRO |
| Go Direct 650 mAh Replacement Battery | GDX-BAT-650 |
| Motion Detector Clamp | MD-CLAMP |
| Motion Detector Bracket | DTS-MDB |

Warranty

Warranty information for this product can be found on the Support tab at www.vernier.com/gdx-md

General warranty information can be found at www.vernier.com/warranty

Disposal

When disposing of this electronic product, do not treat it as household waste. Its disposal is subject to regulations that vary by country and region. This item should be given to an applicable collection point for the recycling of electrical and electronic equipment. By ensuring that this product is disposed of correctly,

you help prevent potential negative consequences on human health or on the environment. The recycling of materials will help to conserve natural resources. For more detailed information about recycling this product, contact your local city office or your disposal service.

Battery recycling information is available at www.call2recycle.org

Do not puncture or expose the battery to excessive heat or flame.



The symbol, shown here, indicates that this product must not be disposed of in a standard waste container.

Federal Communication Commission Interference Statement

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

FCC Caution

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

- (1) this device may not cause harmful interference and
- (2) this device must accept any interference received, including interference that may cause undesired operation

RF Exposure Warning

The equipment complies with RF exposure limits set forth for an uncontrolled environment. The antenna(s) used for this transmitter must not be co-located or operating in conjunction with any other antenna or transmitter. You are cautioned that changes or modifications not expressly approved by the party responsible for compliance could void your authority to operate the equipment.

IC Statement

This device complies with Industry Canada license-exempt RSS standard(s). Operation is subject to the following two conditions:

- (1) this device may not cause interference, and
- (2) this device must accept any interference, including interference that may cause undesired operation of the device.

Industry Canada - Class B This digital apparatus does not exceed the Class B limits for radio noise emissions from digital apparatus as set out in the interference-causing equipment standard entitled “Digital Apparatus,” ICES-003 of Industry Canada. Operation is subject to the following two conditions: (1) this device may not cause interference, and

- (2) this device must accept any interference, including interference that may cause undesired operation of the device.

To reduce potential radio interference to other users, the antenna type and its gain should be so chosen that the equivalent isotropically radiated power (e.i.r.p.) is not more than that permitted for successful communication.

RF exposure warning: The equipment complies with RF exposure limits set forth for an uncontrolled environment. The antenna(s) used for this transmitter must not be co-located or operating in conjunction with any other antenna or transmitter.

Le présent appareil est conforme aux CNR d’Industrie Canada applicables aux appareils radio exempts de licence. L’exploitation est autorisée aux deux conditions suivantes :

- (1) l’appareil ne doit pas produire de brouillage, et
- (2) l’appareil doit accepter toute interférence radioélectrique, même si cela résulte à un brouillage susceptible d’en compromettre le fonctionnement.


Cet appareil numérique respecte les limites de bruits radioélectriques applicables aux appareils numériques de Classe B prescrites dans la norme sur le matériel interférant-brouilleur: “Appareils Numériques,” NMB-003 édictée par Industrie Canada. L’utilisation est soumise aux deux conditions suivantes:

- (1) cet appareil ne peut causer d’interférences, et
- (2) cet appareil doit accepter toutes interférences, y comprises celles susceptibles de provoquer un dysfonctionnement du dispositif.

Afin de réduire les interférences radio potentielles pour les autres utilisateurs, le type d’antenne et son gain doivent être choisis de telle façon que l’équivalent de puissance isotrope émis (e.i.r.p) n’est pas plus grand que celui permis pour une communication établie.

Avertissement d'exposition RF: L'équipement est conforme aux limites d'exposition aux RF établies pour un environnement non supervisé. L'antenne (s) utilisée pour ce transmetteur ne doit pas être jumelés ou fonctionner en conjonction avec toute autre antenne ou transmetteur.

Note: This product is a sensitive measurement device. For best results, use the cables that were provided. Keep the device away from electromagnetic noise sources, such as microwaves, monitors, electric motors, and appliances.



Vernier Software & Technology
13979 SW Millikan Way • Beaverton, OR 97005-2886
Toll Free (888) 837-6437 • (503) 277-2299 • Fax (503) 277-2440
info@vernier.com • www.vernier.com

Rev. 3/25/2021

Go Direct, Vernier Graphical Analysis, and other marks shown are our trademarks or registered trademarks in the United States. All other marks not owned by us that appear herein are the property of their respective owners, who may or may not be affiliated with, connected to, or sponsored by us.

The Bluetooth® word mark and logos are registered trademarks owned by the Bluetooth SIG, Inc. and any use of such marks by Vernier Software & Technology is under license. Other trademarks and trade names are those of their respective owners.